



SOAP AND TOWEL DISPENSERS

PLACEMENT	LIMITS
SIDE REACH – CLEAR FLOOR SPACE	15” MINIMUM – 48” MAXIMUM TO DISPENSER CONTROL
SIDE REACH – OVER OBSTRUCTION	44” MAXIMUM TO DISPENSER CONTROL
FORWARD REACH – CLEAR FLOOR SPACE	15” MINIMUM – 48” MAXIMUM TO DISPENSER CONTROL
FORWARD REACH OVER OBSTRUCTION UNDER 20” DEEP	48” MAXIMUM TO DISPENSER CONTROL
FORWARD REACH OVER OBSTRUCTION 20” – 25” DEEP	44” MAXIMUM TO DISPENSER CONTROL
OPERATION OF DISPENSER CONTROLS	LIMITS
OPERABLE WITH ONE HAND AND CANNOT REQUIRE TIGHT GRASPING, PINCHING OR TWISTING OF THE WRIST	5 LBF (POUNDS OF FORCE) MAXIMUM FORCE TO ACTIVATE

TOILET TISSUE DISPENSERS

PLACEMENT	LIMITS
NEAR SIDE INSTALLATION	19” – 48” ABOVE THE FLOOR TO THE CENTER OF THE ROLL. LOCATE 7” – 9” FROM FRONT OF TOILET. MAY BE LOCATED ABOVE GRAB BAR WITH MINIMUM 12” CLEARANCE. MUST HAVE 1 ½” CLEARANCE IF LOCATED BELOW GRAB BAR.

PROTRUDING OBJECTS

PLACEMENT	LIMITS
BOTTOM EDGES BETWEEN 27” AND 80” ABOVE THE FLOOR	PROTRUSION MUST BE 4” OR LESS INTO A WALKWAY OR CLEAR FLOOR AREA.